

Rainbow City Fire Department

Food Truck Fire Safety Checklist

LPG Containers and Piping

LPG mounted securely
Containers protected against impact
Protection of cylinder valve
Shut off valve is readily accessible
Flexibility between regulator and fixed piping

LPG Appliances

Appliances should be readily accessible
Appliances shall not block egress

Hood System

Fire extinguisher in hood with tag
Proper ventilation and grease filters
Hood cleaned at regular intervals
Ext. system serviced every 6 months

Fire Extinguishers

All cooking vehicles 2A 10BC
K extinguisher if required
Carbon monoxide detector

Access

Fire apparatus access roads shall not be obstructed

Electrical

Electrical panels shall be accessible
Extension cords should not replace permanent wiring
(Should expect exterior cords)
No open junction box
Safe use of generators

General Requirements

No smoking sign
Business license/permit
No fueling during event or with public present